



Well Water Test Report  
Specialty LLC, NC DPH/EPA Lab ID 37909  
336.510.7333  
[SpecialtyTesting.com](http://SpecialtyTesting.com)

**Report ID:** 12912152100180  
**Report Date:** 12/16/2021  
**Client or Representative:** Hometek Inspection Services, LLC  
**Location Address:** 123 Sample Rd. Snow Camp, NC 27349  
**Sample Collected by:** Collected and delivered by independent home inspector  
**Sample Analysis by:** JED, GAP  
**Sample Results:**

**No failures reported; all requested and performed tests PASSED EPA and local requirements.**

All performed inorganic chem or microbiological tests were NEGATIVE or below maximum contaminant (reporting) levels.

Coliform Presence/Absence: Test was NEGATIVE for Coliforms (Not present / <1 CFU/100 mL) - PASS

E. coli Presence/Absence: Test was NEGATIVE for E. coli (Not present / <1 CFU/100 mL) - PASS

Selected analyte reported levels:

Nitrate levels reported below 10 mg/L (10ppm) - PASS

Nitrite levels reported below 1 mg/L (1ppm) - PASS

Lead levels reported below 0.015 mg/L (15ppb) - PASS

Testing performed by Specialty LLC, NC EPA Laboratory ID Number 37909, Microbiology and Inorganic Chemistry Certifications.

This is a true and certified copy of an original report kept by Specialty Testing.

All legal agreements and terms of this report and its use are available at [SpecialtyTesting.com](http://SpecialtyTesting.com)

A handwritten signature in cursive script, appearing to read "Elizabeth Paul", is written in black ink.

\_\_\_\_\_  
Authorized Laboratory Personnel

12/16/2021

\_\_\_\_\_  
Date

Thank you for using Specialty Testing

For further testing, or to refer someone else to us, please visit [www.SpecialtyTesting.com](http://www.SpecialtyTesting.com).